

## **Summary of Plan Changes**

Sheet	Changes
Sheets C-101 and C-102	<ul> <li>Added reference to recorded Subdivision plans for boundary</li> <li>Added abutters</li> <li>Added existing property line bisecting site</li> <li>Added location of existing 18" pipe crossing Summit Ave.</li> <li>Added approximate existing tree line</li> <li>Added additional survey information of Beacon Street</li> <li>Added existing utility information</li> </ul>
Sheets C-201 and C-202	<ul> <li>Added proposed site signage locations</li> <li>Added traffic signage on Summit Ave</li> <li>Added centerline layout info</li> <li>Slide Clubhouse away from drive +/-10'</li> <li>Added Clubhouse patio and stair</li> <li>Reconfigure Clubhouse parking and H/C space</li> <li>Revise light pole locations</li> <li>Added concrete driveway apron</li> </ul>
Sheets C-203 thru C-206	Added road profiles to Set
Sheets C-301 and C-302	<ul> <li>Revised grading at entrances to provide a minimum of 60' at 3% slope</li> <li>Revise drainage to provide 3'min. cover were possible</li> <li>Added wall adjacent to unit 51</li> </ul>
Sheets C-401 and C-402	Revise sewer elevations to provide min. 7' cover
Sheets C-403 thru C-405	Revise sewer elevation to provide min. 7' cover
Sheet C-601	No Change
Sheet C-602	<ul><li>Added trail details</li><li>Added detail of concrete driveway apron</li></ul>
Sheet C-603	No Change
Sheet C-604	<ul><li>Revise light pole base detail</li><li>Added trench patch detail</li></ul>
Sheet C-605	<ul> <li>Revise sections so drywell is in section</li> </ul>